# **Guide to Alternative Refrigerants**



**Genetron® Refrigerants** 

## **Commercial Refrigeration**

## **Long Term Refrigerants**

ASHRAE #	Trade Name	Manufacturer	Replaces	Type (b) (e)	Typical Lubricant (a)	Applications	Comments
<b>R-404A</b> 125/143a/134a (44%/52%/4%)	Genetron 404A Suva HP62 Forane 404A	Honeywell DuPont Arkema	R-502 R-22 HP-80 R-408A	Blend HFC (low glide)	Synthetic (POE, PVE etc.)	New Equipment Retrofits	Most widely used low and medium temperature replacement.
<b>R-507</b> 125/143a (50%/50%)	Genetron AZ-50 Suva 507	Honeywell DuPont	R-502 R-22 HP-80 R-408A	Azeotrope (no glide) HFC	Synthetic (POE, PVE etc.)	New Equipment Retrofits	Slightly higher pressures and efficiency than R404A Best choice for systems with flooded evaporators.
R-422A 125/134a/600a (851%/115%/3.4%)	One Shot Isceon 79	ICOR DuPont	R-502 R-22	Blend HFC	Synthetic (POE, PVE etc.)	New Equipment Retrofits	Similar performance to R-404A.  Equipment with suction line accumulators and receivers should use synthetic oils to avoid oil return issues.
R-422D 125/134a/600a (65.1/31.5/3.4)	Genetron422D Isceon MO 29	Honeywell DuPont	R-22	Blend (moderate glide) HFC	Mineral Oil POE	New Equipment Retrofits	Lower capacity Use of POE will enhance oil return, if required.
R-407C 32/125/134a (23%/25%/52%)	Genetron 407C Suva 9000 Forane 407C	Honeywell DuPont Arkema	R-22	Blend (high glide) HFC	Synthetic (POE, PVE etc.)	New Equipment Retrofits	Reasonable performance match to R-22 in medium temperature refrigeration. Lower capacity in low temperature refrigeration system.
R-134a	Genetron 134a Suva 134a Forane 134a Klea 134a	Honeywell DuPont Arkema INEOS	R-12	Single Component Fluid HFC	Synthetic (POE, PVE etc.)	New Equipment	Performs well in small hermetic systems.

## **Interim HCFC Based Refrigerants**

		•					
ASHRAE #	Trade Name	Manufacturer	Replaces	Type (b) (e)	Typical Lubricant (a)	Applications (c)	Comments
<b>R-401A</b> 22/152a/124 (53%/13%/34%)	Genetron MP39 Suva MP39	Honeywell DuPont	R-12	Blend (moderate glide) HCFC/HFC	Alkylbenzene Synthetic (POE, PVE etc.) Mineral Oil	Med Temp Retrofits (c)	In most cases no oil change is needed. Best for applications with >0 degrees F suction.
<b>R-401B</b> 22/152a/124 (61%/11%/28%)	Genetron MP66 Suva MP66	Honeywell DuPont	R-12 R-500	Blend (moderate glide) HCFC/HFC	Alkylbenzene Synthetic (P0E, PVE etc.) Mineral Oil	Transport Refrigeration Low Temp Retrofits <sup>(c)</sup> Retrofits including air conditioners and dehumidifiers.	In most cases no oil change is needed. Best for low temp R-12 and R-500 retrofit applications.
R-409A 22/124/142b (60%/25%/15%)	Genetron 409A Suva 409A Forane FX-56	Honeywell DuPont Arkema	R-12 R-500	Blend (high glide) HCFC	Alkylbenzene Synthetic (POE, PVE etc.) Mineral Oil	Retrofits <sup>(e)</sup> Low and Med Temp	In most cases no oil change is needed. Good broad range R-12 substitute.
<b>R-402A</b> 125/290/22 (60%/2%/38%)	Genetron HP80 Suva HP80	Honeywell DuPont	R-502	Blend (low glide) HFC/HC/HCFC	Alkylbenzene Synthetic (POE, PVE etc.)	Retrofits Low and Med Temp	Most widely used R-502 retrofit substitute. Higher discharge pressure than R-502. Use either synthetic oil or blend of AB/MO with AB>50%.
<b>R-402B</b> 125/290/22 (38%/2%/60%)	Genetron HP81 Suva HP81	Honeywell DuPont	R-502	Blend (low glide) HFC/HC/HCFC	Alkylbenzene Synthetic (POE, PVE etc.)	Ice Machines	Niche refrigerant used in some ice machines.
<b>R-408A</b> 125/143a/22 (7%/46%/47%)	Genetron 408A Suva 408A Forane FX-10	Honeywell DuPont Arkema	R-502	Blend (low glide) HFC/HCFC	Alkylbenzene Synthetic (POE, PVE etc.)	Retrofits Low and Med Temp	Works well as R-502 substitute. Higher discharge temperatures than R-502. Use either synthetic oil or blend of AB/M0 with AB>50%.

## **Ultra Low Temp Refrigerants**

ASHRAE #	Trade Name	Manufacturer	Replaces	Type (b) (e)	Typical Lubricant (a)	Applications	Comments
R-23	Genetron 23 Suva 23	Honeywell DuPont	R-13 R-503	Single Component Fluid HFC	Synthetic (POE, PVE etc.)	New Equipment Retrofits	Higher discharge temperatures than R-13 or R-508B
<b>R-508B</b> 23/116 (46%/54%)	Genetron 508B Suva 95	Honeywell DuPont	R-13 R-503	Azeotrope HFC	Synthetic (POE, PVE etc.)	New Equipment Retrofits	Lower discharge temperatures than R-13 and R-23. Good performance match to R-503.

### **Air Conditioning**

### **Centrifugal Chiller Refrigerants**

ASHRAE #	Trade Name	Manufacturer	Replaces	Type (b) (e)	Typical Lubricant (a)	Applications	Comments
R-123	Genetron 123 Suva 123 Forane 123	Honeywell DuPont Arkema	R-11	Single Component Fluid HCFC	Alkylbenzene Mineral Oil Synthetic (POE, PVE etc.)	New Equipment Retrofits	Due for phase out in 2030
R-245fa	Genetron 245fa	Honeywell	R-11	Single Component Fluid HFC	Synthetic (POE, PVE etc.)	New Equipment	Equipment redesign Organic Rankine Cycle & as Heat Transfer Fluid
R-134a	Genetron 134a Suva 134a Forane 134a Klea 134a	Honeywell DuPont Arkema INEOS	R-12 R-500	Single Component Fluid HFC	Synthetic (POE, PVE etc.)	New Equipment Retrofits	Used in many new chiller designs.

### Long Term Refrigerants — Air Conditioning and Heat Pumps

ASHRAE #	Trade Name	Manufacturer	Replaces	Type (b) (e)	Typical Lubricant (a)	Applications	Comments
<b>R-407C</b> 32/125/134a (23%/25%/52%)	Genetron 407C Suva 407C Forane 407C	Honeywell DuPont Arkema	R-22 R-500	Blend (high glide) HFC	Synthetic (POE, PVE etc.)	New Equipment Retrofits	Best retrofit alternative to R-22. Close performance match with slightly higher operating pressures.
R-410A 32/125 (50%/50%)	Genetron AZ-20 <sup>(TM)</sup> Suva 410A Forane 410A Puron	Honeywell DuPont Arkema	R-22	Azeotropic Mixture (near zero glide) HFC	Synthetic (POE, PVE etc.)	New Equipment	High pressure, high efficiency refrigerant designed for new equipment. NOT FOR RETROFITTING.
R-422D 125/134a/600a (65.1/31.5/3.4)	Genetron422D Isceon MO 29	Honeywell DuPont	R-22	Blend (moderate glide) HFC	Mineral Oil POE	New Equipment Retrofits	Lower capacity Use of POE will enhance oil return, if required.
R-134a	Genetron 134a Suva 134a Forane 134a Klea 134a	Honeywell DuPont Arkema INEOS	R-12 R-500	Single Component Fluid (no glide) HFC	Synthetic (POE, PVE etc.)	New Equipment Retrofits	Used in large screw chillers

#### R22 Phase-out Schedule for Air Conditioning and Refrigeration

35% reduction in HCFC consumption required by Montreal Protocol. No new R-22 can be manufactured for new equipment manufactured January 1, 2004: January 1, 2010:

or imported in US or Canada. 65% reduction in HCFC consumption

required by Montreal Protocol.

90% reduction in HCFC consumption required by Montreal Protocol

January 1, 2015:

No new R-22 refrigerant can be manufactured or imported

into the US or Canada.

Any servicing must be done using stockpiled or reclaimed material. 100% reduction in HCFC consumption required by Montreal Protocol.

#### Notes

- (a) Check with the compressor manufacturer for their recommended lubricant.
- (b) Interim replacements contain HCFCs that are scheduled for phase out. (c) Not recommended for automotive air conditioning.

#### Disclaimer

All statements, information and data given herein are believed to be accurate and reliable but are presented without guaranty, warranty or responsibility of any kind, expressed or implied. Statements or suggestions concerning possible use of our products are made without representation or warranty that any such use is free of patent infringement and are not recommendations to infringe any patent. The user should not assume that all safety measures are indicated, or that other measures may not be required.

- (d) The refrigerant R-600 is butane. The refrigerant R-600a is isobutane.
- (e) CFC=Chlorofluorocarbon: HCFC=Hydrochlorofluorocarbon: HFC=Hydrofluorocarbon HC=Hydrocarbon: FC=Fluorocarbon

#### **Trademarks**

Genetron, AZ-20, AZ-50 are registered trademarks of Honeywell International

Puron is a registered trademark of Carrier Corporation Klea is a registered trademark of INEOS Suva is a registered trademark of DuPont

Forane is a registered trademark of Arkema Isceon is a registered trademark of DuPont

